

GENERAL NOTES

(continued)

11. All As-Built Record Drawings shall clearly depict utility lines that were constructed along with their respective easement (if required). As-Built Record Drawings will not be accepted unless the verbiage "PROPOSED" and/or "TO BE CONSTRUCTED" have been deleted on the drawing. As-Built Record Drawings with "PROPOSED" or "TO BE CONSTRUCTED" terminology will not be accepted.
12. All new utility construction located within the rights-of-way, easements and alike shall be tied to the respective rights-of-way, easement, etc. every 1,000 feet and change of direction.
13. All As-Built Record Drawings shall be complete and approved before commencement of field test.
14. Baseline of construction and station of items to be located on the center of the roadway, unless conditions warrant and approved by IRCDUS. Baseline stationing shall be every 100', control points set at every 500' and at angle change of direction.
15. All new utility construction lines on all As-Built Record Drawings shall be shown with a wider, solid line. Existing utility lines shall be shown with a thinner, dashed line.
16. Top of pipe elevations & stationing to be typed, listed, sealed & submitted by the engineer for locating the air release valves as construction proceeds.
17. Show top elevation of the utility lines that were constructed and show existing utility lines for all utility crossings.
18. Pump station power supply from FP&L or COVB electric power pole or transformer to the pump station electric panel shall be included on the As-Built Record Drawing.
19. All fire hydrants and fire hydrant valves shall be located by state plane coordinates, station number and offset and shall be clearly identified on the As-Built Record Drawing.
20. All newly constructed valves shall be clearly identified by size, type, top elevation and direction/number of turns to open or close valve.

-ART-

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITIES SERVICES



AS-BUILT
RECORD DRAWING
GENERAL NOTES
(CONTINUED)

MARCH 2018

DRAWING
NO.
M-16