



PLAN VIEW

-ART-

NOTES

1. VALVE BOX LID SHALL BE PAINTED:
 - BLUE - WATER
 - GREEN - FORCE MAINS
 - PURPLE - REUSE WATER
 - BROWN - BRINE
2. IN UNPAVED AREAS (SEE M-5, TYPE II) A BRASS VALVE INDICATOR IS TO BE PROVIDED WITH ENGRAVED DIAGRAM OF VALVE LOCATION AND DESCRIPTION. (SEE EXAMPLE ABOVE) INDICATOR SHALL BE FLUSH WITH PAD/PAVEMENT.
3. VALVE BOX LID LOCATED IN PAVEMENT SHALL BE A DUCTILE IRON STAY-PUT COVER, MINIMUM 24 LBS. WITH A MINIMUM 6" LONG THROUT AND SHALL BE MARKED WITH RAISED LETTERS: "WATER", "SEWER", "BRINE", OR "REUSE WATER" AS APPLICABLE.
4. VALVE BOX SHALL COMPLY WITH FDOT STANDARDS AS APPLICABLE.
5. NO VALVE RINGS ARE TO BE USED.
6. IN TYPE I, PAVED AREAS, THE VALVE BOX PAD TOP ELEVATION SHALL BE EVEN WITH THE ROCK GRADE TO ALLOW BOTH LAYERS OF ASPHALT TO COVER THE VALVE BOX PAD WITH THE FINAL ASPHALT LAYER FLUSH WITH THE TOP OF THE VALVE BOX.

INDIAN RIVER COUNTY
 DEPARTMENT OF
 UTILITIES SERVICES



VALVE BOX PAD

DRAWING
 NO.
 M-6

MARCH 2014