



-ART-

NOTES

1. AIR RELEASE VALVE IS TO BE LOCATED INSIDE A CONCRETE MANHOLE WITH HINGED LID. ALL MATERIALS PER IRCUDS APPROVED MANUFACTURER'S LIST
2. MANHOLES FOR SEWER FORCE MAINS SHALL BE COATED. ALL COATING MATERIAL SHALL BE PER IRCUDS APPROVED MANUFACTURERS' PRODUCT LIST.
3. SEE AIR RELEASE DETAIL M-18.
4. SEE TRACER WIRE DETAIL M-13.
5. WASTEWATER LIDS SHALL BE VENTED.
6. SEAL SHALL BE USED AT ALL JOINTS. SEE MANHOLE NOTES, S-5, NOTE 20.
7. OPENING AT BOTH SIDES OF THE MANHOLE TO BE SEALED WITH MATERIALS PER IRCUDS APPROVED MANUFACTURERS' PRODUCT LIST.

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITY SERVICES



AIR RELEASE VALVE MANHOLE
BELOW GROUND
(AUTOMATIC - WATER/WASTEWATER)

MARCH 2018

DRAWING
NO.

M-7