



NOTES

1. AUTOMATIC AIR RELEASE VALVE TO BE LOCATED ONLY WHERE CONDITIONS MAKE IT INACCESSABLE OR AS REQUIRED BY THE IRCDUS.
2. AIR RELEASE RISERS TO BE IN A VERTICAL POSITION AND PLACED AT SUMMITS IN THE SYSTEM. FOR DIRECTIONAL DRILLS, AIR RELEASE VALVES TO BE PLACED ON EITHER SIDE OF THE CROSSING.
3. SEE TRACER WIRE DETAIL. M-13.
4. IF FORCE MAIN IS 8" OR LARGER A 4" TAP AND AIR RELEASE VALVE SHALL BE USED. FORCE MAIN 4" OR SMALLER CONSULT IRCDUS ENGINEERING.

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITIES SERVICES



ABOVE GROUND
AIR RELEASE VALVE DETAIL
(AUTOMATIC - WATER/WASTEWATER)

MARCH 2014

DRAWING
NO.
M-8

-ART-