



NOTES

1. ALL ABOVE GROUND PIPING SHALL BE PAINTED PANTONE PURPLE (522C).
2. PROVIDE A PLACARD WITH THE WORDS "RECLAIMED WATER IN USE."
3. ALL MATERIALS ARE TO BE PER IRCDUS APPROVED MANUFACTURERS' PRODUCT LIST.
4. DISCHARGE INVERT TO BE ONE PIPE DIAMETER (MINIMUM) ABOVE METER TO MAINTAIN FULL PIPE.
5. A TELEMETRY AND MONITORING DEVICE IS REQUIRED AT DISCHARGE, AS APPROVED BY IRCDUS. EQUIPMENT SHALL BE INSTALLED IN STRICT ACCORDANCE WITH MANUFACTURERS INSTRUCTIONS.

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITIES SERVICES



REUSE PIPE
DISCHARGE DETAIL

DRAWING
NO.

R-2

MARCH 2014