



**NOTES**

1. SANITARY SEWER LATERALS SHALL BE A MINIMUM OF 6" IN DIAMETER.
2. MAGNETIC DETECTION TAPE SHALL BE INSTALLED OVER TOP OF ALL SEWER MAINS AND SERVICE LATERALS.
3. ALL MATERIALS ARE TO BE PER IRCDUS APPROVED MANUFACTURERS' PRODUCT LIST.
4. 4" ELECTRONIC MARKER BALLS TO BE TAPED TO 6"x4" WYE 24" BELOW FINISHED GRADE.
5. FOR RISER AND CLEANOUT DETAIL SEE DRAWING S-3.  
AND FOR CUTTING SEWER CLEANOUT TO FINISH GRADE PRIOR TO CONNECTION. SEE DETAIL S-3.
6. RISERS AND CLEANOUT SHALL NOT BE CONSTRUCTED WITHIN 12" OF SIDEWALK.

INDIAN RIVER COUNTY  
DEPARTMENT OF  
UTILITY SERVICES



STANDARD LATERAL  
(SHALLOW SEWER)

DRAWING NO.

S-1

MARCH 2018