



NOTE:
 1/2" PREFORMED JOINT MATERIAL TO BE PLACED BETWEEN PIPE AND CONCRETE OR PIPE SLEEVE FOR ALL PIPES ENTERING OR EXITING THE VALVE VAULT AND WETWELL EXCEPT FOR INFLUENT PIPES

ALL HARDWARE SHALL BE 316 STAINLESS STEEL SEE S-20 FOR PUMP STATION GENERAL NOTES SEE S-21 FOR PUMP STATION ELECTRICAL & EMERGENCY GENERATOR NOTES

ELEVATION
 N.T.S.

MARCH 2018

-ART-

DRAWING
 NO. S-15

SCHEMATIC: NOT INTENDED FOR CONSTRUCTION. SEE PROJECT PLANS.

INDIAN RIVER COUNTY
 DEPARTMENT OF
 UTILITY SERVICES



TYPICAL WASTEWATER
 PUMPING STATION
 WETWELL/VALVE VAULT CROSS SECTION