



NOTES

1. 3/4" GRAVEL BEDDING SHALL BE USED FOR EXCAVATION IN ROCK. SAND BEDDING SHALL BE USED FOR EXCAVATION IN SAND.
2. ALL MATERIALS ARE TO BE PER IRCDUS APPROVED MANUFACTURERS' PRODUCT LIST.
3. MARKER BALLS TO BE TAPED TO 6"x4" 24" BELOW FINISHED GRADE.
4. PLUMBING CONTRACTOR SHALL BE RESPONSIBLE FOR RISER PIPE WITH BEND FOR SERVICE CONNECTION AND FOR SETTING 4" SEWER CLEANOUT TO FINISH GRADE PRIOR TO CONNECTION.
5. RISERS AND CLEANOUTS SHALL NOT BE CONSTRUCTED WITHIN 12" OF SIDWALK.

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITY SERVICES



MODIFIED RISER LATERAL
(DEEP SEWER)

DRAWING
NO.

S-2

MARCH 2018