



DETAIL

-ART-

NOTES

1. ALL SEWER LATERALS (SINGLE, DOUBLE, DEEP OR SHALLOW) SHALL HAVE A RISER PIPE WITH BENDS AS REQUIRED FOR SERVICE CONNECTIONS AND WITH A 4" SEWER CLEANOUT AT FINISHED GRADE.
2. PLUMBING CONTRACTOR WILL BE RESPONSIBLE FOR RISER PIPE WITH BEND FOR SERVICE CONNECTION AND FOR CUTTING 4" SEWER CLEANOUT TO FINISH GRADE PRIOR TO CONNECTION.
3. MARKER BALLS TO BE TAPED TO 6"x4" 24" BELOW FINISHED GRADE.
4. ALL MATERIALS ARE TO BE PER IRCUDS APPROVED MANUFACTURERS' PRODUCT LIST.

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITIES SERVICES



SEWER LATERAL RISER
(DEEP OR SHALLOW SEWER)

MARCH 2014

DRAWING
NO.

S-3