



ELEVATION

-ART-

NOTES

1. TIE-IN VALVE SHALL BE OPERATED BY IRCDUS PERSONNEL ONLY AND IN THE PRESENCE OF THE ENGINEER OF RECORD.
2. ALL LINES TO BE FULL PIPE FLUSHED.
3. ALL MATERIALS TO BE PER IRCDUS APPROVED MANUFACTURERS' PRODUCT LIST.
4. A 2" TEMPORARY JUMPER TO BE USED UNLESS OTHERWISE DIRECTED BY IRCDUS.
5. CORP STOP SHALL BE PLUGGED AFTER REMOVAL/ABANDONMENT OF TEMPORARY JUMPER.
6. WHEN JUMPER IS NO LONGER REQUIRED, SERVICE SHALL BE ADANDONED AND PLUGGED AT MAIN.
7. FIELD INSPECTION BY IRCDUS IS REQUIRED BEFORE UTILITIES ARE ACCEPTED.

INDIAN RIVER COUNTY  
DEPARTMENT OF  
UTILITIES SERVICES



TEMPORARY  
JUMPER DETAIL

DRAWING  
NO.

W-13

MARCH 2014