



ELEVATION

-ART-

NOTES

1. A TEMPORARY JUMPER CONNECTION IS TO BE USED FOR FILLING ANY NEW WATER MAIN OF ANY SIZE FROM THE EXISTING ACTIVE WATER MAINS AND FOR THE FLUSHING OF NEW MAINS UP TO 6" DIAMETER (2.5 FPS MINIMUM VELOCITY) AND FOR PULLING BACTERIOLOGICAL SAMPLES FROM ANY NEW WATER MAIN OF ANY SIZE.
2. TIE-IN VALVE SHALL BE OPERATED BY IRCBUS PERSONNEL ONLY AND IN THE PRESENCE OF THE ENGINEER OF RECORD.
3. IRCBUS SHALL PROVIDE METER AFTER APPLICATION FOR SERVICE AND AFTER THE DEPOSIT AND ALL FEES HAVE BEEN PAID.
4. A 2" TEMPORARY JUMPER TO BE USED UNLESS OTHERWISE DIRECTED BY IRCBUS.
5. ALL INSTALLATION AND MAINTENANCE OF THE TEMPORARY JUMPER CONNECTION AND ASSOCIATED BACKFLOW PREVENTION DEVICE, FITTINGS, VALVES, ETC., SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.
6. ALL MATERIALS TO BE PER IRCBUS APPROVED MANUFACTURERS' PRODUCT LIST.
7. VERTICAL PIPING FOR THE JUMPER SHALL BE SCHEDULE 40 OR 80 PVC OR SDR CTS PE TUBING. IF PE TUBING IS USED, A BRASS CURB STOP IS REQUIRED.
8. SEE DRAWING W-14 FOR CONTINUATION OF NOTES.

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITY SERVICES



TEMPORARY
JUMPER DETAIL

DRAWING
NO.

W-13

MARCH 2018