



NOTES

1. BLOW-OFF TO BE LOCATED AT ALL DEAD END LINES AND ALIGNED WITH PROPERTY LINES AS REQUIRED BY IRCDUS.
2. ALL MATERIALS ARE TO BE PER IRCDUS APPROVED MANUFACTURERS' PRODUCT LIST.
3. METHODS OF RESTRAINT AS APPROVED BY IRCDUS.
4. TRACE WIRE TO BE INSTALLED AS PER DETAIL M-13.
5. ELECTRONIC MARKER BALLS ARE TO BE LOCATED ADJACENT TO ALL VALVE BOXES AND PLACED IN ALL METER BOXES WITHIN 24" FROM SURFACE.
6. ALL BLOW-OFFS SHALL BE LOCATED FROM 4'-6' OF THE TERMINAL VALVE.

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITY SERVICES



MANUAL
2" BLOW-OFF

MARCH 2018

DRAWING
NO.

W-3