

WHEN METERS CANNOT BE LOCATED IMMEDIATELY INSIDE THE RIGHT OF WAY
 THEY MAY BE LOCATED INSIDE THE PROPERTY LINE AS DIRECTED BY IRCUDS

FIBERGLASS REINFORCED POLYMER (FRP) CONCRETE
 SOLID HEAVY DUTY TRAFFIC BEARING METER BOX LID
 WITH SKID RESISTANT SURFACE, LIFT SLOT & 316 SS PIN

MARKER
 PAINTED BLUE

ETCH CURB WITH "W" FOR
 WATER SERVICE

SEE W-7 PRE-PLUMBED METER BOX

1", 1 1/2" OR 2"
 CORP STOP

90° ANGLE CURB STOP

FINISHED GRADE

2'-0"

ROADWAY

5'-0"
 SIDEWALK

1'-0"
 6" MIN

36" (MIN)
 COVER

TRACE WIRE
 (SEE DETAIL M-13)

METER

LONG SERVICE

PVC CASING SLEEVE
 (EXTEND UNDER SIDEWALK
 PER IRCUDS)

4" MARKER BALL
 INSIDE BOTTOM ALL METERS

RUBBER GASKET REQ'D
 SEE W-7

WATER MAIN

DOUBLE STRAP
 SERVICE SADDLE

RIGHT-OF-WAY

PROPERTY LINE

ELEVATION

MARCH 2018

-ART-

DRAWING
 NO.
 W-5

SEE NOTES
 W-4

INDIAN RIVER COUNTY
 DEPARTMENT OF
 UTILITY SERVICES



WATER SERVICE
 (OUTSIDE RIGHT-OF-WAY)