



NOTES

1. METERS OVER 2"Ø MUST BE APPROVED BY IRCDUS AND SHALL BE SUPPLIED AND INSTALLED BY THE DEVELOPER/PROPERTY OWNER.
2. ALL METERS 2"Ø AND SMALLER WILL BE SUPPLIED AND INSTALLED BY IRCDUS.
3. MINIMUM SIZE OF METER BOXES: 1"Ø SERVICE (12" X 18"); 1-1/2"Ø AND 2"Ø SERVICE (17" X 28").
4. TRACE WIRE (NOT SHOWN) TO BE INSTALLED AS PER DETAIL M-13.
5. PLACE A 4" ELECTRONIC MARKER BALL IN THE INSIDE BOTTOM OF ALL METER BOXES.
6. ALL METER BOXES SHALL BE PER IRCDUS APPROVED MANUFACTURERS' PRODUCT LIST.

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITY SERVICES



METER BOX

DRAWING
NO.

W-6

MARCH 2018