



NOTES

1. METERS OVER 2" ϕ MUST BE APPROVED BY IRCDUS AND INSTALLED BY CONTRACTOR.
2. ALL METERS 2" ϕ AND SMALLER WILL BE SUPPLIED AND INSTALLED BY IRCDUS.
3. MINIMUM SIZE OF METER BOXES: 1" ϕ SERVICE (12" X 18"); 1-1/2" ϕ AND 2" ϕ SERVICE (17" X 28").
4. METERS GREATER THAN 2" ϕ SHALL BE COMPOUND METERS. REFER TO IRCDUS APPROVED MANUFACTURERS' PRODUCT LIST.
5. TRACE WIRE (NOT SHOWN) TO BE INSTALLED AS PER DETAIL M-13.
6. LOCATE MARKER BALLS ARE TO BE LOCATED ADJACENT TO ALL INLINE VALVE BOXES AND PLACED IN ALL METER BOXES WITHIN 24" FROM SURFACE.
7. PRE-PLUMBED METER BOXES PER IRCDUS APPROVED MANUFACTURERS' PRODUCT LIST.

INDIAN RIVER COUNTY
DEPARTMENT OF
UTILITIES SERVICES



METER BOX

DRAWING
NO.

W-6

MARCH 2014